

**Top Ten Deficiencies National and Virginia
Life Safety Code
Long Term Care**

RANK	NATIONAL 2010	VIRGINIA 2010	VIRGINIA 2009	VIRGINIA 2008
#1	K0147. Electrical wiring and equipment	K0147. Electrical wiring and equipment	K0062. Sprinkler system maintenance	K0147. Electrical wiring and equipment
#2	K0062. Sprinkler system maintenance	K0062. Sprinkler system maintenance	K0147. Electrical wiring and equipment	K0018. Corridor doors
#3	K0018. Corridor doors	K0018. Corridor doors	K0018. Corridor doors	K0062. Sprinkler system maintenance
#4	K0029. Hazardous areas - separation	K0029. Hazardous areas - separation	K0025. Smoke partition construction	K0029. Hazardous areas - separation
#5	K0038. Exit Access	K0038. Exit Access	K0038. Exit Access	K0025. Smoke partition construction
#6	K0025. Smoke partition construction	K0025. Smoke partition construction	K0029. Hazardous areas - separation	K0038. Exit Access
#7	K0144. Generator inspected/tested	K0027 Doors in Smoke Partitions	K0027. Doors in smoke partitions.	K0056. Automatic Sprinkler system
#8	K0050. Fire drills	K0056. Automatic Sprinkler system	K0144. Generator inspected/tested	K0052. Testing of the fire alarm
#9	KOO12 Construction Type	K0052. Testing of the fire alarm.	K0052. Testing of the fire alarm.	K0027. Doors in smoke partitions.
#10	K0056. Automatic Sprinkler system	KO130 Other	K0056. Automatic Sprinkler system	K0069. Cooking equipment

2/25/2011